



PBS Number
5-436143

New York State Department of Environmental Conservation
PETROLEUM BULK STORAGE CERTIFICATE
625 Broadway, 11th Floor, Albany, NY 12233-7020 Phone: 518-402-9553

Region 5 NYSDEC - PBS Unit
P.O. Box 296
1115 State Route 86
Ray Brook, NY 12977-0296

TANK NUMBER	TANK SUBPART	TANK CATEGORY	TANK LOCATION	DATE INSTALLED	TANK TYPE	PRODUCT STORED	CAPACITY (GALLONS)
003	4	2	Aboveground on saddles, legs, stilts, rack or cradle	03/01/1993	Steel/Carbon Steel/Iron	gasoline/ethanol	1,000 *
16	4	2	Aboveground on saddles, legs, stilts, rack or cradle	09/12/2012	Plastic	motor oil	275 *
17	4	2	Aboveground on saddles, legs, stilts, rack or cradle	09/12/2012	Plastic	waste oil/used oil	275 *
18	4	2	Aboveground on saddles, legs, stilts, rack or cradle	09/13/2012	Plastic	motor oil	275 *
19	4	2	Aboveground on saddles, legs, stilts, rack or cradle	09/13/2012	Plastic	motor oil	110 *
20	4	2	Aboveground on saddles, legs, stilts, rack or cradle	09/13/2012	Plastic	waste oil/used oil	275 *

FACILITY NAME AND ADDRESS :
JACK BYRNE FORD
1003 HUDSON RIVER ROAD
MECHANICVILLE, NY 12118

FACILITY (PROPERTY) OWNER:
BYRNE FAMILY PROPERTIES, LLC
1003 HUDSON RIVER ROAD
MECHANICVILLE, NY 12118

Facility Operator: JACK BYRNE FORD

Tank Owner Name:
Jack Byrne Ford

Emergency Contact Name: JOHN BYRNE
Emergency Contact Phone Number: (518) 573-6027

Facility Phone Number
(518) 664-9841

MAILING CORRESPONDENCE:
JOHN BYRNE
JACK BYRNE FORD
P.O. BOX 471
1003 HUDSON RIVER RD.
MECHANICVILLE, NY 12118

ISSUED BY: Commissioner Basil Seggos
PBS NUMBER: 5-436143
DATE ISSUED: 10/24/2017
EXPIRATION DATE : 04/28/2021
FEE PAID: \$300.00

As the owner of this facility and/or the tanks at this facility, the receipt, posting, and use of this certificate is an acknowledgement that I am responsible to the extent required by law for ensuring that this facility is in compliance with all regulations for the bulk storage of petroleum including those regarding equipment requirements, inspections, handling procedures, recordkeeping, registration requirements, providing advanced notice to the Department of major changes to a tank system, spill reporting, and all other applicable requirements. Violations may be punishable as a criminal offense and/or a civil violation in accordance with applicable state and federal law.

This registration certificate must be kept current and conspicuously posted at this facility at all times. Posting must be at the tank, at the entrance of the facility, or the main office where the storage tanks are located.

Spills must be reported to the DEC within two hours (1-800-457-7362).

John P. Byrne 10/25/17
Signature of Facility Owner/Authorized Representative Date
John P. Byrne
Printed Name and Title of Facility Owner/Authorized Representative



PBS Number
5-436143

New York State Department of Environmental Conservation
PETROLEUM BULK STORAGE CERTIFICATE
625 Broadway, 11th Floor, Albany, NY 12233-7020 Phone: 518-402-9553

Region 5 NYSDEC - PBS Unit
P.O. Box 296
1115 State Route 86
Ray Brook, NY 12977-0296

TANK NUMBER	TANK SUBPART	TANK CATEGORY	TANK LOCATION	DATE INSTALLED	TANK TYPE	PRODUCT STORED	CAPACITY (GALLONS)
21	4	2	Aboveground on saddles, legs, stilts, rack or cradle	09/13/2012	Plastic	waste oil/used oil	275 *

* Tank requires monthly visual inspections and may need documented internal inspections as described in 6NYCRR Section 613-4.3.

PBS regulations are available at http://www.dec.ny.gov/docs/remediation_hudson_pdf/part613text.pdf.

FACILITY NAME AND ADDRESS :
JACK BYRNE FORD
1003 HUDSON RIVER ROAD
MECHANICVILLE, NY 12118

FACILITY (PROPERTY) OWNER:
BYRNE FAMILY PROPERTIES, LLC
1003 HUDSON RIVER ROAD
MECHANICVILLE, NY 12118

As the owner of this facility and/or the tanks at this facility, the receipt, posting, and use of this certificate is an acknowledgement that I am responsible to the extent required by law for ensuring that this facility is in compliance with all regulations for the bulk storage of petroleum including those regarding equipment requirements, inspections, handling procedures, recordkeeping, registration requirements, providing advanced notice to the Department of major changes to a tank system, spill reporting, and all other applicable requirements. Violations may be punishable as a criminal offense and/or a civil violation in accordance with applicable state and federal law.

Facility Operator: JACK BYRNE FORD

Emergency Contact Name: JOHN BYRNE
Emergency Contact Phone Number: (518) 573-6027

Tank Owner Name:
Jack Byrne Ford

Facility Phone Number
(518) 664-9841
MAILING CORRESPONDENCE:

This registration certificate must be kept current and conspicuously posted at this facility at all times. Posting must be at the tank, at the entrance of the facility, or the main office where the storage tanks are located.

ISSUED BY: Commissioner Basil Seggos
PBS NUMBER: 5-436143
DATE ISSUED: 10/24/2017
EXPIRATION DATE: 04/28/2021
FEE PAID: \$300.00

JOHN BYRNE
JACK BYRNE FORD
P.O. BOX 471
1003 HUDSON RIVER RD.
MECHANICVILLE, NY 12118

Spills must be reported to the DEC within two hours (1-800-457-7362).

Signature of Facility Owner/Authorized Representative: *John P. Byrne* Date: 10/25/17
Printed Name and Title of Facility Owner/Authorized Representative



PBS # :
5-436143

NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION
Petroleum Bulk Storage Program
Facility Information Report

Printed : 10/24/2017

pbsfacrpt_foil.rpt

Site Information

JACK BYRNE FORD
1003 HUDSON RIVER ROAD
MECHANICVILLE, NY 12118

Tax Map Information

Boro/Sec.:
Block:
Lot:

Site Owner Information

BYRNE FAMILY PROPERTIES, LLC
1003 HUDSON RIVER ROAD
MECHANICVILLE, NY 12118

(518) 573-6027

Mail Correspondent Information

JACK BYRNE FORD
P.O. BOX 471
1003 HUDSON RIVER RD.
MECHANICVILLE, NY 12118

Site Phone: (518) 664-9841
Town: Halfmoon County: Saratoga
Facility Operator: JACK BYRNE FORD

Owner Type : Corporate/Commercial/Other

ATTN: JOHN BYRNE
(518) 664-9841

Authorized Representative: JOHN BYRNE

Emergency Contact: JOHN BYRNE

Emergency Phone: (518) 573-6027

Site Status : Active		Reg Expires : 04/28/2021		Cert Printed: 10/24/2017		Total Active Tanks : 7		Last Inspected: 10/13/2017																
Site Type: Auto Service/Repair (No Gasoline Sales)				Cert Issued: 10/24/2017				Total Active Capacity : 2,485				Inspected By: Benjamin Hankins												
(2) Tank No	(3) Tank Loc	(4) Status	(5) Date Instal	(5) Date Closed	(6) Capacity (gals)	(7) Product	(8) Tank Type	(9) Tank IP	(10) Tank EP	(11) Tank SC	(12) Tank LD	(13) Tank OP	(14) Tank SP	(15) Tank Disp	(16) Pine Loc	(17) Pine Type	(18) Pine EP	(19) Pine SC	(20) Pine LD	(21) UDC	Next Tank Test	Next Line Test	Tank Owner	
003	3	1	03/01/1993		1,000	2712	01	00	01	01	10	06	04	05	01	02	01	02	00	00				Jack Byrne Ford
Subpart: 4		Category: 2																						
16	3	1	09/12/2012		275	0015	07	00	05	12	02	04	00	02	01	01	01	00	00				Jack Byrne Ford	
Subpart: 4		Category: 2																						
17	3	1	09/12/2012		275	0022	07	00	05	12	02	04	00	00	00	00	00	00	00				Jack Byrne Ford	
Subpart: 4		Category: 2																						
18	3	1	09/13/2012		275	0015	07	00	05	12	02	04	00	02	01	01	01	00	00				Jack Byrne Ford	
Subpart: 4		Category: 2																						
19	3	1	09/13/2012		110	0015	07	00	05	12	02	04	00	02	01	01	01	00	00				Jack Byrne Ford	
Subpart: 4		Category: 2																						
20	3	1	09/13/2012		275	0022	07	00	05	12	02	04	00	00	00	00	00	00	00				Jack Byrne Ford	
Subpart: 4		Category: 2																						
21	3	1	09/13/2012		275	0022	07	00	05	12	02	04	00	00	00	00	00	00	00				Jack Byrne Ford	
Subpart: 4		Category: 2																						
001	5	3	01/01/1979	06/01/1992	1,000	0009	01	00	00	00	00	00	02	00	02	00								
004	5	3	06/01/1992	11/07/2012	1,000	0009	01	00	01	00	00	05	00	02	03	02	00	00	00					
02	3	3	05/01/2003	08/27/2012	300	0022	01	00	00	00	06	04	00	02	01	01	00	00	00					
03	3	3	01/01/2000	09/12/2012	275	0015	01	00	00	00	06	04	00	02	01	01	00	00	00					
04A	3	3	01/01/2000	09/12/2012	550	0015	01	00	00	00	06	04	00	02	01	01	00	00	00					



PBS # :
5-436143

NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION
Petroleum Bulk Storage Program
Facility Information Report

Printed : 10/24/2017

pbsfacrpt_foils.rpt

Page 2 of 3

Site Information

JACK BYRNE FORD
1003 HUDSON RIVER ROAD
MECHANICVILLE, NY 12118

Tax Map Information

Boro/Sec.:
Block:
Lot:

Site Owner Information

BYRNE FAMILY PROPERTIES, LLC
1003 HUDSON RIVER ROAD
MECHANICVILLE, NY 12118

Mail Correspondent Information

JACK BYRNE FORD
P.O. BOX 471
1003 HUDSON RIVER RD.
MECHANICVILLE, NY 12118

Site Phone: (518) 664-9841

Town: Halfmoon County: Saratoga

Facility Operator: JACK BYRNE FORD

(518) 573-6027

Owner Type : Corporate/Commercial/Other

ATTN: JOHN BYRNE

(518) 664-9841

Authorized Representative: JOHN BYRNE

Emergency Contact: JOHN BYRNE

Emergency Phone: (518) 573-6027

Site Status : Active		Reg Expires : 04/28/2021		Cert Printed: 10/24/2017		Total Active Tanks : 7		Last Inspected: 10/13/2017															
Site Type: Auto Service/Repair (No Gasoline Sales)				Cert Issued: 10/24/2017		Total Active Capacity : 2,485		Inspected By: Benjamin Hankins															
(2) Tank No	(3) Tank Loc	(4) Status	(5) Date Instal	(5) Date Closed	(6) Capacity (gals)	(7) Product	(8) Tank Type	(9) Tank IP	(10) Tank EP	(11) Tank SC	(12) Tank LD	(13) Tank OP	(14) Tank SP	(15) Tank Disp	(16) Pipe Loc	(17) Pipe Type	(18) Pipe EP	(19) Pipe SC	(20) Pipe LD	(21) UDC	Next Tank Test	Next Line Test	Tank Owner
04B	3	3	01/01/2000	09/12/2012	0	0015	01	00	00	00	06	04	00	02	01	01	00	00	00				
05	3	3	01/01/2000	09/12/2012	275	0021	01	00	00	00	06	04	00	02	01	01	00	00	00				
06	3	3	01/01/2000	08/27/2012	300	0022	01	00	00	00	06	04	00	02	01	00	00	00	00				
07	3	3	01/01/2007	09/12/2012	275	0015	01	00	00	00	06	04	00	02	01	01	00	00	00				
08	3	3	01/01/2000	09/13/2012	275	0015	01	00	00	00	06	04	00	02	01	01	00	00	00				
09	3	3	01/01/2000	09/13/2012	275	0015	01	00	00	00	06	04	00	02	01	01	00	00	00				
10	3	3	01/01/2000	08/27/2012	275	0022	01	00	00	00	06	04	00	02	01	00	00	00	00				
11	3	3	05/01/2003	08/27/2012	300	0022	01	00	00	00	06	04	00	02	01	01	00	00	00				
12	3	3	09/05/2011	08/27/2012	300	0022	01	00	00	00	06	04	00	02	01	00	00	00	00				
13	3	3	09/05/2011	08/27/2012	275	0022	01	00	00	00	06	04	00	02	01	00	00	00	00				
14	3	3	09/05/2011	08/27/2012	300	0022	01	00	00	00	06	04	00	02	01	00	00	00	00				
002	5	4	01/01/1986	08/01/2003	1,000	0022	01	00	00	00	00	00		02	02	02	00						

(See Reverse Side or Last Page for Code Keys)

PETROLEUM BULK STORAGE APPLICATION - SECTION B - TANK INFORMATION - CODE KEYS

<p><u>Action (1)</u></p> <ol style="list-style-type: none"> Initial Listing Add Tank Close/Remove Tank Information Correction Recondition/Repair/Reline <p><u>Tank Location (3)</u></p> <ol style="list-style-type: none"> Aboveground-contact w/soil Aboveground-contact w/ impervious barrier Aboveground on saddles, leggs, stilts, rack or cradle Tank 10% or more below ground Underground including vaulted with no access for inspection Aboveground in Subterranean <p><u>Status (4)</u></p> <ol style="list-style-type: none"> In-service Out-of-service Closed-Removed Closed- In Place Tank converted to Non-Regulated use <p><u>Products Stored (7)</u></p> <p><u>Heating Oils: On-Site Consumption</u></p> <ol style="list-style-type: none"> #2 Fuel Oil #4 Fuel Oil #5 Fuel Oil #6 Fuel Oil Kerosene Clarified Oil Biodiesel (Heating) Used Oil (Heating) <p><u>Heating Oils: Resale/Redistribution</u></p> <ol style="list-style-type: none"> #2 Fuel Oil #4 Fuel Oil #5 Fuel Oil #6 Fuel Oil Kerosene Clarified Oil Biodiesel (Heating) 	<p><u>Motor Fuels</u></p> <ol style="list-style-type: none"> Gasoline Gasoline/Ethanol Diesel Biodiesel Jet Fuel Jet Fuel (Biofuel) Aviation Gasoline <p><u>Lubricating/Cutting Oils</u></p> <ol style="list-style-type: none"> Lube Oil Motor Oil Gear/Spindle Oil Hydraulic Oil Cutting Oil Transmission Fluid Turbine Oil <p><u>Oils Used as Building Materials</u></p> <ol style="list-style-type: none"> Asphaltic Emulsions Form Oil <p><u>Petroleum Spirits</u></p> <ol style="list-style-type: none"> White/Mineral Spirits Naphtha <p><u>Mineral/Insulating Oils</u></p> <ol style="list-style-type: none"> Insulating Oil (e.g., Transformer, Cable Oil) Mineral Oil <p><u>Waste/Used/Other Oils</u></p> <ol style="list-style-type: none"> Waste/Used Oil Other-Please list * <p><u>Crude Oil</u></p> <ol style="list-style-type: none"> Crude Oil Crude Oil Fractions <p><u>Tank Type (8)</u></p> <ol style="list-style-type: none"> Steel/Carbon Steel/Iron Galvanized Steel Alloy Stainless Steel Alloy Fiberglass Coated Steel Steel Tank in Concrete Fiberglass Reinforced Plastic (FRP) Plastic Equivalent Technology Concrete Urethane Clad Steel Other-Please list.* 	<p><u>Internal Protection (9)</u></p> <ol style="list-style-type: none"> None Epoxy Liner Rubber Liner Fiberglass Liner (FRP) Glass Liner Jet Fuel Other-Please list.* <p><u>External Protection (10/18)</u></p> <ol style="list-style-type: none"> None Painted/Asphalt Coating Original Sacrificial Anode Original Impressed Current Fiberglass Jacketed Wrapped (Piping) Retrofitted Sacrificial Anode Retrofitted Impressed Current Urethane <p><u>Tank Secondary Containment (11)</u></p> <ol style="list-style-type: none"> None Diking (AST Only) Vault (w/access) Vault (w/o access) Double-Walled (UST Only) Synthetic Liner Remote Impounding Area Excavation Liner Modified Double-Walled (AST Only) Impervious Underlayment (AST Only)** Double Bottom (AST Only)** Double-Walled (AST Only) Other - Please List.* <p><u>Tank Leak Detection (12)</u></p> <ol style="list-style-type: none"> None Interstitial Electronic Monitoring Interstitial Manual Monitoring Vapor Well Groundwater Well In-Tank System (Auto Tank Gauge) Impervious Barrier/Concrete Pad (AST Only) Statistical Inventory Reconciliation (SIR) Weep holes in vaults with no access for inspection. 	<p><u>Overfill Protection (13)</u></p> <ol style="list-style-type: none"> None Float Vent Valve High Level Alarm Automatic Shut-Off Product Level Gauge (AST) Vent Whistle Other-Please list.* <p><u>Spill Prevention (14)</u></p> <ol style="list-style-type: none"> None Catch Basin Other-Please list.* <p><u>Pumping/Dispensing Method (15)</u></p> <ol style="list-style-type: none"> None Presurized Dispenser Suction Dispenser Gravity On-Site Heating System (Suction) On-Site Heating System (Supply/Return) Tank-Mounted Dispenser <p><u>Piping Location (16)</u></p> <ol style="list-style-type: none"> No Piping Aboveground Underground/On-ground Aboveground/Underground Combination <p><u>Piping Type (17)</u></p> <ol style="list-style-type: none"> None Steel/Carbon Steel/Iron Galvanized Steel Stainless Steel Alloy Fiberglass Coated Steel Steel Encased in Concrete Fiberglass Reinforced Plastic (FRP) Plastic Equivalent Technology Concrete Copper Flexible Piping 	<p><u>Piping Secondary Containment (19)</u></p> <ol style="list-style-type: none"> None Diking (Aboveground Only) Vault (w/access) Double-Walled (Underground Only) Remote Impounding Area Trench Liner Double-Walled (Aboveground Only) Other - Please List.* <p><u>Pipe Leak Detection (20)</u></p> <ol style="list-style-type: none"> None Interstitial Electronic Monitoring Interstitial Manual Monitoring Vapor Well Groundwater Well Pressurized Piping Leak Detector Exempt Suction Piping Statistical Inventory Reconciliation (SIR) Other-Please list.* <p><u>Under Dispenser Containment (UDC) (21)</u></p> <p>Check Box if Present _____</p> <p>* If other, please list on a separate sheet including tank number</p> <p>** Each of these codes must be combined with code 01 or 06 to meet compliance requirements</p>
---	--	---	---	---